




# **Setup for Electrical Power Measurements at Metrosert, Estonia**

Andrei Pokatilov


CMI, 10.06.2016

# Measurement Setup

- Multiharmonic least-squares fitting algorithm



Method A and C



Method B




# Method C

External sampling interval  $t_{\text{sel}}$  is applied to both DMMs:


$$t_{\text{sel}} = t_s + \Delta t, \text{ where}$$

$t_s$  - internal sampling interval in  $\mu\text{s}$ ,

$\Delta t$  - time shift less than one half of the internal clock resolution.  $\Delta t = 45 \text{ ns}$ .




Sampling time jitter (solid line) on the left vertical axis.



Repeating jitter pattern with  $\Delta t = 45 \text{ ns}$  on the left vertical axis.

# Standard Deviation of Phase difference Estimate



- 50 measurements of 1000 samples,  $f_{in} = 50$  Hz to 20 kHz



Standard deviation  $s_{\Delta\hat{\theta}}$  of the phase difference estimate  $\Delta\hat{\theta}$  for three synchronization modes as a function of frequency  $f$ .

# Voltage and Current Transducers

- Resistive voltage dividers up to 240 V;  
<100  $\mu$ rad at 20 kHz




- Current shunts Fluke A40A up to 20 A  
<40  $\mu$ rad at 5 kHz for 20 A shunt



# Phantom Power Sources

## (1) Modular setup



## (2) CALMET CP11B (class 0.02)





# ***Kontaktandmed***

AS Metrosert

Teaduspargi 8, Tallinn 12618

Estonia

[andrei.pokatilov@metrosert.ee](mailto:andrei.pokatilov@metrosert.ee)

+372 529 7095